



ASSOCIATION
Certification testing center
(Association SIC)

building 4, 34 Oktyabrskaya naberezhnaya Street, Saint-Petersburg, 193091
702 7883
www.npsic.ru E-mail: npsic@npsic.ru

ATTN: O.N. Ekaterinina
Director General
of SKB EP, LLC

Our ref No.13 from 11.03.2022

Review of MIKO-10 instrument.

Dear Olga Nikolaevna!

Since 07.2020 micro-ohmmeter MIKO-10 manufactured by SKB EP, LLC has been used in our testing laboratory of IL Association SIC.

This instrument is used to check contact joints according to GOST 10434 and GOST 17441, as well as for measuring the grounding resistance of metal parts of the NKU RU (low-voltage switchgears according to GOST R 51321.1).

Due to the low weight, compact size and presentation of measurement results in digital form and also the availability of test wires set for various purposes, it is very convenient to use the instrument. In our test laboratory (IL) the «Single-10A» mode (in accordance with the requirements of GOST-s) is used frequently during operation.

As we do not need to identify malfunctions or failures of the test NKU RU, it is not possible to count the economic effect of instrument operation.

MIKO-10 micro-ohmmeter can be recommended for purchase by all organizations conducting acceptance tests, qualifying, periodic or certification tests of NKU RU or other types of electrotechnical products.

Expert of SIC Association

I.A. Brener