



Kambaratinskiye HPP  
the branch of Electric stations, JSC  
72100, Kyrgyz Republic  
Zhalal-Abad region, Kara-Kul  
M. Sabirova st.  
Tel./fax: +996 (3746) 5-14-76  
E-mail: kambarges@mail.ru  
TIN 40102200810055

ATTN: O.N. Ekaterinina  
Director General  
of SKB EP, LLC

Review to MIKO-2.3 device

Dear Olga Nikolaevna!

MIKO-2.3 devices have been in operation at our enterprise since 2018. During the operation, devices have proven themselves as reliable, multifunctional, compact. The device is convenient to carry out measurements, and it also has the function of automatic recalculation of measurement results. MIKO-2.3 device is used at Kambaratinskiye HPP for contact resistance measurements on disconnectors of RGN-110 type, SF6 circuit breakers of VGT-110 type, current transformers, voltage transformers, power transformers and electric motors of all capacities. No malfunctions were detected during the use of the device.

The disadvantage of MIKO-2.3 is the rapid discharge of the battery when using the microohmmeter mode.

Using this device, we have reduced the total amount of time spent for measurements and tests.

Taking into account the above, we can recommend this device for specialists of electrical laboratories of various enterprises.

Best regards,  
Engineer for HV testing  
of KAGES-2 EC



B.O. Abatov